


GARAGE VENTILATION TABULATION

NET GARAGE FLOOR AREA = 5000 SQ. FT.
 MEASURED FROM INSIDE FACE OF EXTERIOR WALLS
 TWO STAIRCASE & METER ROOM DEDUCTED.

PARKING AREA (NET) = 5000 SQ. FT.
 REQ'D EXHAUST AIR PER sq. ft.: 1.5 CFM.
 TOTAL EXHAUST AIR REQ'D = 5000 x 1.5 = 7500 CFM.
 PROPOSED EXHAUST FAN TO HAVE 8,000 CFM CAPACITY

- (CO) CARBON MONOXIDE SENSOR
- (D) 24"X30" GARAGE EXHAUST DUCT UTR
- (G) 34"X12" GARAGE EXHAUST GRILL
- (L) 36"X16" LOUVER ABOVE DOOR
- (V) 4"Ø DRYER VENT
- (V2) 4"Ø DRYER VENT UP TO 1ST FLOOR, LOCATED 3' AWAY FROM ANY OPENING TO BUILDING, & 3' Ø AWAY FROM PROPERTY LINE



GARAGE LEVEL FLOOR PLAN

scale 1/4"=1'-0"

- LEGEND:
- 4" WALL
 - 6" WALL
 - CONCRETE WAL
 - FIRE & SOUND CONCRETE SLA
 - UNEXCAVATED

No.	REVISION	DATE

L&V ARCHITECTS
 1514 17th Street, Suite 207
 Santa Monica, CA 90404
 Tel. (310) 829 0996; Fax. (310) 829 7889

MR. ALI MADANI & MR. HOSSEIN ASHTIANI
 5 UNIT CONDOMINIUMS at
 1327 EUCLID STR., SANTA MONICA, CA-90404

TITLE
GARAGE LEVEL FLOOR PLAN

SCALE
1/4"=1'-0"

DATE
2-19-07

SCHELET NUMBER
M-2