



FIRST FLOOR HVAC PLAN

scale 1/4"=1'-0"

- LEGEND:
- 4" WALL
 - 6" WALL
 - 6" FIRE & SOUND WRAPPED CEILING

- 01 24"X30" GARAGE EXHAUST DUCT UR
- 02 16"X16" SUPPLY DUCT FROM AC UNIT ON ROOF
- 03 16"X16" RETURN DUCT UP TO AC UNIT ON ROOF
- 04 4"Ø BATHROOM EXHAUST DUCT
- 05 KITCHEN EXHAUST FAN
- 06 6"X4" DRYER VENT EXHAUST LOUVER TO MATCH BUILDING EXTERIOR
- 07 PER ARCHITECT'S SELECTION, LOCATED 3' AWAY FROM ANY OPENING TO BUILDING
- 08 10"X6" BATHROOM EXHAUST LOUVER TO MATCH BUILDING EXTERIOR
- 09 PER ARCHITECT'S SELECTION, LOCATED 3' AWAY FROM ANY OPENING TO BUILDING
- 10 8"X4" AWAY FROM PROPERTY LINE
- 11 10"X6" KITCHEN VENT EXHAUST LOUVER TO MATCH BUILDING EXTERIOR
- 12 PER ARCHITECT'S SELECTION, LOCATED 3' AWAY FROM ANY OPENING TO BUILDING
- 13 8"X4" AWAY FROM PROPERTY LINE
- 14 30"X18" RETURN GRILL
- 15 8"X6" SIDE WALL SUPPLY AIR REGISTER (75 CFM - 150 CFM)
- 16 10"X6" SIDE WALL SUPPLY AIR REGISTER (151 CFM - 200 CFM)
- 17 12"X6" SIDE WALL SUPPLY AIR REGISTER (201 CFM - 250 CFM)
- 18 14"X6" SIDE WALL SUPPLY AIR REGISTER (251 CFM - 300 CFM)
- 19 4"Ø DRYER VENT
- 20 4"Ø DRYER VENT FROM GARAGE, LOCATED 3' AWAY FROM ANY OPENING TO BUILDING
- 21 8"X4" AWAY FROM PROPERTY LINE
- 22 7"Ø KITCHEN VENT
- 23 4"Ø WATER HEATER VENT