



- Ⓛ1 24"x30" GARAGE EXHAUST DUCT UTR
- Ⓛ2 18"x16" SUPPLY DUCT FROM AC UNIT ON ROOF
- Ⓛ3 16"x16" RETURN DUCT UP TO AC UNIT ON ROOF
- Ⓛ4 4"Ø BATHROOM EXHAUST DUCT
- Ⓛ5 KITCHEN EXHAUST FAN
- Ⓛ6 10"x6" BATHROOM EXHAUST LOUVER TO MATCH BUILDING EXTERIOR
- PER ARCHITECT'S SELECTION, LOCATED 3' AWAY FROM ANY OPENING TO BUILDING.
- Ⓛ7 8"x6" AWAY FROM PROPERTY LINE
- Ⓛ8 8"x6" SIDE WALL SUPPLY AIR REGISTER (101 CFM - 150 CFM)
- Ⓛ9 10"x6" SIDE WALL SUPPLY AIR REGISTER (151 CFM - 200 CFM)
- Ⓛ10 12"x6" SIDE WALL SUPPLY AIR REGISTER (201 CFM - 250 CFM)
- Ⓛ11 14"x6" SIDE WALL SUPPLY AIR REGISTER (251 CFM - 300 CFM)

SECOND FLOOR HVAC PLAN

scale 1/4"=1'-0"

- LEGEND:
- 4" WALL
 - 6" WALL
 - 6" FIRE & SOUND RATED
 - W/SHIPPED CEILING AREA



MR. ALI MADANI & MR. HOSSEIN ASHTIANI
 5 UNIT CONDOMINIUMS at
 1327 EUCLID STR., SANTA MONICA, CA-90404

L&V ARCHITECTS
 1514 17th Street, Suite 207
 Santa Monica, CA 90404
 Tel. (310) 829 0996; Fax. (310) 829 7889

TITLE
SECOND FLOOR HVAC PLAN
 SCALE
 1/4"=1'-0"
 DATE
 2-19-07
 SHEET NUMBER
M-4

No.	REVISION	DATE