



- (D1) 24"x30" GARAGE EXHAUST DUCT UTR
- (D2) 18"x18" SUPPLY DUCT FROM AC UNIT ON ROOF
- (D3) 18"x18" RETURN DUCT UP TO AC UNIT ON ROOF
- (D4) 4"Ø BATHROOM EXHAUST DUCT
- (D5) 4"Ø BATHROOM EXHAUST DUCT UP TO ROOF
- (E1) KITCHEN EXHAUST FAN
- (E2) 10"x6" BATHROOM EXHAUST LOUVER TO MATCH BUILDING EXTERIOR
- PER ARCHITECT'S SELECTION, LOCATED 3' AWAY FROM ANY OPENING TO BUILDING.
- (S1) 8"x6" SIDE WALL SUPPLY AIR REGISTER (101 CFM - 150 CFM)
- (S2) 10"x6" SIDE WALL SUPPLY AIR REGISTER (151 CFM - 200 CFM)
- (S3) 12"x6" SIDE WALL SUPPLY AIR REGISTER (201 CFM - 250 CFM)
- (S4) 14"x6" SIDE WALL SUPPLY AIR REGISTER (251 CFM - 300 CFM)

THIRD FLOOR HVAC PLAN

scale 1/4"=1'-0"

- LEGEND:
- 4" WALL
 - 6" WALL
 - 6" FIRE & SOUND RATED
 - DRAPPED CEILING AREA



MR. ALI MADANI & MR. HOSSEIN ASHTIANI
5 UNIT CONDOMINIUMS at
1327 EUCLID STR., SANTA MONICA, CA-90404

L&V ARCHITECTS
 1514 17th Street, Suite 207
 Santa Monica, CA 90404
 Tel. (310) 829 0996; Fax. (310) 829 7889

TITLE
THIRD FLOOR HVAC PLAN

SCALE
 1/4"=1'-0"

DATE
 2-19-07

SHEET NUMBER
M-5

No.	REVISION	DATE