



1 FIRST FLOOR DECK PLAN
SCALE: 1/4"=1'-0"

1. SEE SHEET S-1.1 FOR MATERIAL SPECIFICATIONS & NOTES.
2. STRENGTH OF CONCRETE FOR CONCRETE DECK & CONC. BEAM & CONC. COL. 4-4000 PSI (28 DAYS).
3. STRENGTH OF REINFORCING STEEL BARS IS F_y=60 ksi.
4. ALL ANCHOR BOLTS TO BE 5/8" A.B. 1/2" LONG AT EMBEDMENT & 49" O.C. UNO HOLES SHALL BE 1/16" OVERSIZED AT THE CONNECTOR OF THE ANCHOR BOLT POST WHICH SHALL BE VERIFIED AT THE JOB SITE BY THE INSPECTOR.
5. **●** INDICATES CONC. BEAM NUMBER. SEE DETAIL 15/S-3.1.
6. **BM** INDICATES CONC. BEAM NUMBER. SEE DETAIL 15/S-3.1.
7. ALL STRUCTURAL STUDS TO BE 3x4 @ 16" O.C. UNO.
8. ALL SILL PLATE SHOULD BE 6x TREATED WOOD.
9. ALL ANCHOR BOLTS SHOULD BE 1/2" DIA. UNO.
10. ANCHOR BOLT SCHEDULE AND SPACING SHALL TRACKS SEE SHEAR WALL SCHEDULE.
11. ALL NON BEARING PARTITIONS TO BE 2x4 STUDS @ 16" O.C. UNO.
12. HOLD-DOWN CONNECTOR BOLTS INTO WOOD FLOORING REQUIRE APPROVED PLATE WASHERS AND HOLD-DOWNS SHALL BE TIGHTENED 1ST PRIOR TO COVERING THE WALL FRAMING.

STL COLUMN SCHEDULE

COLUMN TYPE	BASE PLATE
M2400	M20"x16"x3/4" B.P.L. W6-1 1/2 @ A.B. X4" EMBED. W44XK1/2" WAGNER
M2400	M20"x16"x3/4" B.P.L. W6-1 1/2 @ A.B. X4" EMBED. W44XK1/2" WAGNER
M2400	M20"x14"x3/8" B.P.L. W4-5/8 @ A.B. X4" EMBED. W44XK1/2" WAGNER
M2400	M20"x12"x3/8" B.P.L. W4-5/8 @ A.B. X4" EMBED. W44XK1/2" WAGNER



MR. ALI MADANI & MR. HOSSEIN ASHTIANI
5 UNIT CONDOMINIUMS at
1327 EUCLID STR., SANTA MONICA, CA-90404

L&V ARCHITECTS
1514 17th Street, Suite 207
Santa Monica, CA 90404
Tel. (310) 829 0996; Fax. (310) 829 7889

No.	REVISION	DATE